

**ST. PETERSBURG COLLEGE**  
**Facilities Services Department**  
**EpiCenter, Services Building, Room 252, 14025 58<sup>th</sup> Street North**  
**Clearwater, Florida 33760-3768**

April 22nd, 2015

Attention: Contractors who plan on participating with a bid response to ITB #SPC 09-14-15, Arts Auditorium (AA) Building, Air Handling Unit Replacement, Clearwater Campus, Located at 2465 Drew St., Clearwater Florida 33765

**ADDENDUM #2**

**Time of Construction and Completion:** Contractors will have full access to the AA building during the project construction schedule between **July 1<sup>st</sup>, 2015 and September 13<sup>th</sup>, 2015**. Therefore, the bidder shall prepare the Bid to allow for construction to occur not only during regular construction hours but also on Saturdays, Sundays, and legal holidays, if needed, in order to ensure completion by the September 13<sup>th</sup>, 2015 deadline. All after hour work shall be coordinated through John Shoffner, Facilities Supervisor with advanced notice. Normal working hours are defined as Monday through Friday 7:00 a.m. – 3:30 p.m.

**Owner Direct Purchase:** Due to the long lead times of the mechanical equipment St. Petersburg College will purchase these items directly. **DO NOT INCLUDE THE COST OF THE FOLLOWING UNITS IN YOUR BIDS!**

- **Air handling Unit (AHU-2)**
- **Air handling Unit (AHU-3)**
- **Fan Coil Unit (FCU-1)**

The Bidder must include pricing of all labor and other equipment, ducting, supports, piping, dampers, variable frequency drives, valves, controls, controls interface, etc. in Bid to complete this project with the exception of these three package units that will be delivered to the Site for the Contractor to take delivery of.

**Question:** Verify that 40' of double wall will be required for the supply and return duct for each air handler.

**Answer:** New/replacement ductwork for the supply and return mains within the first 40' of the AHU shall be double wall. Ductwork replacement is limited to the lengths shown on the drawings.

**ST. PETERSBURG COLLEGE**  
Facilities Services Department  
EpiCenter, Services Building, Room 252, 14025 58<sup>th</sup> Street North  
Clearwater, Florida 33760-3768

**Acknowledgment of Receipt of ADDENDUM #2**

Date: \_\_\_\_\_

This will acknowledge that \_\_\_\_\_  
**Name of Contractor**

**Received Addendum #2 To:** ITB #SPC 09-14-15, Arts Auditorium for Air Handler Unit Replacement, Clearwater Campus.

By: \_\_\_\_\_ **Authorized Signature**

\_\_\_\_\_  
**Printed or Typed Signature Name/Title**

Address: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Include this page with your proposal**

**End of Addendum #2**

