



### **Addendum No. 1**

Project: ST. PETERSBURG COLLEGE  
INVITATION TO BID, SPC PROJECT # 265-H-18-8  
DUCTWORK REPAIR & REPLACEMENT, Health Education Center

Date: 05/04/2018

This document is intended to clarify questions asked during the pre-bid walkthrough.

1. The project scope is limited to ductwork pertaining to RTU # 1 only.
2. Refer to Scope of Work note #3 in DWG M1.1, for removal and replacement of ceiling tiles.
3. St. Petersburg College will be responsible for removing computer stations to provide access for ductwork replacement.
4. Wifi routers will be relocated by St. Petersburg College prior to the project start date.
5. Connection of smoke detectors to the fire alarm system should be coordinated through APG, BJ Klingensmith 727-530-0077. Cost to reconnect, add, and/or replace detectors will be the responsibility of the prime contractor.
6. Ductwork pressure testing and test and balance will be provided by St. Petersburg College.

End of Addendum No.1

**SUBMIT A SIGNED COPY OF THIS PAGE WITH BID DOCUMENTS.**